

Project Name: TRIGGER RAIN 27 28 3 2014

Workgroup: ES1407045

Published Date: 16-Apr-2014

Licensee: Murrumbidgee Irrigation

Sampled Date: 28-Mar-2014

EPL No. 4651

Location	Asset ID	Analyte	Data	Units	Notify Level	Action Level	ID
YMS		Endosulfan (sum)	<0.010	µg/L	-	-	9758
YMS		Endrin	<0.010	µg/L	-	-	9759
YMS		Endrin aldehyde	<0.010	µg/L	-	-	9760
YMS		Endrin ketone	<0.010	µg/L	-	-	9761
YMS		Heptachlor	<0.005	µg/L	-	-	9762
YMS		Heptachlor epoxide	<0.010	µg/L	-	-	9763
YMS		Hexachlorobenzene (HCB)	<0.010	µg/L	-	-	9764
YMS		gamma-BHC	<0.010	µg/L	-	-	9765
YMS		Methoxychlor	<0.010	µg/L	-	-	9766
YMS		cis-Chlordane	<0.010	µg/L	-	-	9767
YMS		trans-Chlordane	<0.010	µg/L	-	-	9768
YMS		Total Chlordane (sum)	<0.010	µg/L	-	-	9769
YMS		Oxychlordane	<0.010	µg/L	-	-	9770
YMS		Sum of Aldrin + Dieldrin	<0.010	µg/L	-	-	9771
YMS		Dibromo-DDE	73.5	%	-	-	9772
YMS		Turbidity	499	NTU	-	-	9741
YMS		Nitrite + Nitrate as N	0.65	mg/L	-	-	9742
YMS		Total Kjeldahl Nitrogen as N	1.0	mg/L	-	-	9743
YMS		Total Nitrogen as N	1.6	mg/L	-	-	9744
YMS		Total Phosphorus as P	0.12	mg/L	-	-	9745
YMS		Aldrin	<0.010	µg/L	-	-	9746
YMS		alpha-BHC	<0.010	µg/L	-	-	9747
YMS		beta-BHC	<0.010	µg/L	-	-	9748
YMS		delta-BHC	<0.010	µg/L	-	-	9749
YMS		4.4`-DDD	<0.010	µg/L	-	-	9750
YMS		4.4`-DDE	<0.010	µg/L	-	-	9751
YMS		4.4`-DDT	<0.010	µg/L	-	-	9752
YMS		Sum of DDD + DDE + DDT	<0.010	µg/L	-	-	9753
YMS		Dieldrin	<0.010	µg/L	-	-	9754
YMS		alpha-Endosulfan	<0.010	µg/L	-	-	9755
YMS		beta-Endosulfan	<0.010	µg/L	-	-	9756
YMS		Endosulfan sulfate	<0.010	µg/L	-	-	9757
YMS		Simazine	<0.005	µg/L	3.2000	11.0000	9773
YMS		Diuron	<0.005	µg/L	1.0000	5.0000	9774
YMS		Atrazine	0.013	µg/L	13.0000	45.0000	9775
YMS		Molinate	<0.005	µg/L	3.4000	14.0000	9776
YMS		Metolachlor	0.034	µg/L	0.0200	0.1000	9777
YMS		Malathion	<0.002	µg/L	0.0500	0.2000	9778
YMS		Diazinon	<0.005	µg/L	0.0100	0.2000	9779
YMS		Thiobencarb	<0.005	µg/L	2.8000	4.6000	9780
YMS		Chlorpyrifos	<0.005	µg/L	0.0100	0.1100	9781
YMS		Trifluralin	<0.010	µg/L	2.6000	4.4000	9782

Legend

XX	Notification Level
XX	Action Level